

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Assist. Execut. Engi. P.H. Sub Divisn  
(Name of Officers with designation) from Sri Susanta K. Satpathy PHED (SDO)  
inspected the K.C. PUBLIC SCHOOL Yuvraj Bunglow, Bunglow Street  
(Name & Address of the school) on 07/01/2025 (date of inspection) and on the basis of  
Water Test Report (Attached) bearing no. 138 dated 05/06/2023  
of R.W.S & S. Berhampur (PHED Lab) certified that  
the K.C. PUBLIC SCHOOL (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till 1 year.

Signature with Seal: .....  
Name : .....  
Designation : Assistant Executive Engineer  
Name & Address of the Office/ Department : P.H. Section, Khalikote

To K.C. PUBLIC SCHOOL  
Bunglow Street, Khalikote  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR**

Near Jarda Bunglow, Pin – 760004, Ph. 0680-2296344

eerwss\_bam@nic.inrwssban@gmail.comNo. 138

Date 05.06.2023

To

The Principal,  
 K C Public School,  
 Yuvraj Bunglow, Bunglow Street, Khallikote, Ganjam,  
 Odisha

Sub: Water Quality Test Report of K C Public School.

Ref: Ltr No. KCPS/GC/16/2023 Dtd. 04.06.2023

Sir,

With reference to the above cited subject, the water samples submitted by you at District Water Testing Laboratory , Berhampur. The Following parameters are tested.

Sl. No.	Parameter	Units	Permissible Limit	Testing Values
				Tap Water
1	Alkalinity	Mg/ltr	600	62.0
2	Chloride	Mg/ltr	1000	20.2
3	Fluoride	Mg/ltr	1.5	0.014
4	Total Hardness	Mg/ltr	600	68.0
5	Iron	Mg/ltr	1.0	0.04
6	pH	--	6.5-8.5	6.68
7	Elec. Conductivity	μmho/cm	--	96.4
8	TDS	Mg/ltr	2000	62.66
9	Turbidity	NTU	5	0.23

Water is safe for Drinking because testing values under permissible limit.

Kuna Bhuyan  
 Jr. Lab Asst. S. 6. 2023  
 DLJ, Berhampur  
 Jr. Laboratory Assistant  
 Dist. Water Testing Laboratory  
 R.W.S.S., Berhampur (Gm.)

Q. 61. 27  
 S. 6. 27  
 Executive Engineer (RWSS)  
 Executive Engineer  
 RWS & S Division  
 Berhampur, Gm.