

OFFICE OF THE SUPERINTENDING ENGINEER:RWSS DIVISION:BERHAMPUR

Near Jarda Bungalow, Pin – 760004, Ph. 0680-2296344

eerwss_bam@nic.inrwssban@gmail.comNo. 138

Date 05.06.2023

To

The Principal,
K C Public School,
Yuvraj Bungalow, Bungalow Street, Khallikote, Ganjam,
Odisha

Sub: Water Quality Test Report of K C Public School.

Ref: Ltr No. KCPS/GC/16/2023

Dtd. 04.06.2023

Sir,

With reference to the above cited subject, the water samples submitted by you at District Water Testing Laboratory , Berhampur. The Following parameters are tested.

Sl. No.	Parameter	Units	Permissible Limit	Testing Values
				Tap Water
1	Alkalinity	Mg/ltr	600	62.0
2	Chloride	Mg/ltr	1000	20.2
3	Fluoride	Mg/ltr	1.5	0.014
4	Total Hardness	Mg/ltr	600	68.0
5	Iron	Mg/ltr	1.0	0.04
6	pH	--	6.5-8.5	6.68
7	Elec. Conductivity	μmho/cm	--	96.4
8	TDS	Mg/ltr	2000	62.66
9	Turbidity	NTU	5	0.23

Water is safe for Drinking because testing values under permissible limit.

Kune Bhuyya
Jr. Lab Asst. *5.6.2023*
DLJ, Berhampur
Jr. Laboratory Assistant
Dist Water Testing Laboratory
R.W.S.&S., Berhampur (Gm.)

5.6.23
Executive Engineer(RWSS)
Executive Engineer
RWS & S Division
Berhampur,Gm.